

# Cleanroom Certification


THIS IS TO CERTIFY THAT

**TEXAS SELECT VAPOR – CLEANROOM**  
909 Houston St. Conroe, TX 77301

---

**MEETS OR EXCEEDS ISO CLASS 7 @ .5 MICROMETERS**  
**(<352,000 PARTICLES PER CUBIC METER)**  
**ISO 14644.1:1999**  
**THIS ROOM WAS TESTED “AT REST”**

CERTIFICATION DATE: 10/2014  
EXPIRATION DATE: 10/2015

CERTIFYING SUPERVISOR   
*Performed by: Superior Laboratory Services, Inc.*  
1710 Preston Road, Suite A, Pasadena, Texas 77503  
Office: 713-477-9247 / Fax: 713-477-9248  
Toll Free: 888-561-2932 E:mail:service@slsi.net

